

Measurements recorded in: Metric Imperial

Well Owner's Information

First Name: _____ Last Name/Organization: Vista Invest. Muskoka Inc. E-mail Address: _____ Well Constructed by Well Owner

Mailing Address (Street Number/Name): 36 Gouldie St. Municipality: Huntsville Province: ON Postal Code: R1H1M4 Telephone No. (inc. area code): _____

Well Location

Address of Well Location (Street Number/Name): Pine Haven Estates Township: Huntsville Lot: 11 Concession: _____

County/District/Municipality: Muskoka City/Town/Village: Port Sydney Province: Ontario Postal Code: P0B1L0

UTM Coordinates: Zone: 17Q Easting: 625253 Northing: 5006525 Municipal Plan and Sublot Number: _____ Other: Concessional Rd

Overburden and Bedrock Materials/Abandonment Sealing Record (see instructions on the back of this form)

General Colour	Most Common Material	Other Materials	General Description	Depth (m/ft)	
				From	To
<u>BROWN</u>	<u>SAND</u>	<u>SLT</u>		<u>0</u>	<u>167</u>
<u>GREY</u>	<u>GRANITE</u>		<u>BROKEN</u>	<u>167</u>	<u>168</u>

Annular Space

Depth Set at (m/ft)	Type of Sealant Used (Material and Type)	Volume Placed (m ³ /ft ³)
<u>0 20</u>	<u>BENTONITE</u>	<u>6.9</u>

Results of Well Yield Testing

After test of well yield, water was:	Draw Down		Recovery	
	Time (min)	Water Level (m/ft)	Time (min)	Water Level (m/ft)
<input checked="" type="checkbox"/> Clear and sand free				
<input type="checkbox"/> Other, specify _____				
If pumping discontinued, give reason: _____	Static Level	<u>33'9"</u>		<u>34'8"</u>
	1	<u>34'7"</u>	1	<u>34'</u>
Pump intake set at (m/ft): <u>80</u>	2	<u>34'7.5"</u>	2	<u>34'</u>
Pumping rate (l/min / GPM): <u>5</u>	3	<u>34'9"</u>	3	<u>34'</u>
Duration of pumping: <u>1</u> hrs + _____ min	4	<u>34'8"</u>	4	<u>34'</u>
Final water level end of pumping (m/ft): <u>34'8"</u>	5	<u>34'8"</u>	5	<u>34'</u>
If flowing give rate (l/min/GPM): _____	10	<u>34'8"</u>	10	<u>34'</u>
	15	<u>34'8"</u>	15	<u>34'</u>
	20	<u>34'8"</u>	20	<u>34'</u>
Recommended pump depth (m/ft): <u>80</u>	25	<u>34'8"</u>	25	<u>34'</u>
Recommended pump rate (l/min/GPM): <u>5</u>	30	<u>34'8"</u>	30	<u>34'</u>
Well production (l/min/GPM): <u>20+</u>	40	<u>34'8"</u>	40	<u>34'</u>
Disinfected? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	50	<u>34'8"</u>	50	<u>34'</u>
	60	<u>34'8"</u>	60	<u>34'</u>

Method of Construction

Cable Tool Diamond Public Commercial Not used

Rotary (Conventional) Jetting Domestic Municipal Dewatering

Rotary (Reverse) Driving Livestock Test Hole Monitoring

Boring Digging Irrigation Cooling & Air Conditioning

Air percussion Industrial

Other, specify _____ Other, specify _____

Construction Record - Casing

Inside Diameter (cm/in)	Open Hole OR Material (Galvanized, Fibreglass, Concrete, Plastic, Steel)	Wall Thickness (cm/in)	Depth (m/ft)		Status of Well
			From	To	
<u>6 1/4</u>	<u>STEEL</u>	<u>1.88</u>	<u>+2</u>	<u>168</u>	<input checked="" type="checkbox"/> Water Supply

Construction Record - Screen

Outside Diameter (cm/in)	Material (Plastic, Galvanized, Steel)	Slot No.	Depth (m/ft)		Status of Well
			From	To	
					<input type="checkbox"/> Replacement Well

Water Details

Water found at Depth (m/ft)	Kind of Water: <input checked="" type="checkbox"/> Fresh <input type="checkbox"/> Untested	Hole Diameter	
		Depth (m/ft)	Diameter (cm/in)
<u>168</u>	<input type="checkbox"/> Gas <input type="checkbox"/> Other, specify _____		
		<u>0 20</u>	<u>10</u>
		<u>20 168</u>	<u>6 1/4</u>

Well Contractor and Well Technician Information


Business Name of Well Contractor: Ransome Well Drilling Well Contractor's Licence No.: 7111610

Business Address (Street Number/Name): Box 454 Municipality: Purkiss Falls

Province: ON Postal Code: H0N1C0 Business E-mail Address: _____

Bus. Telephone No. (inc. area code): 705-330-9355 Name of Well Technician (Last Name, First Name): Baker, RICHER (Rob)

Well Technician's Licence No.: 218115 Signature of Technician and/or Contractor: Richer Baker Date Submitted: 20/20/10/23



Comments: FREE CHLORINE RES. 50-100 PPM

Well owner's information package delivered: Yes No

Date Package Delivered: 20/20/10/23

Date Work Completed: 20/20/10/23

Ministry Use Only

Audit No.: Z341298

Received: _____